

GOKUL ENTERPRISES

GROUND WATER CONSULTANTS

No. 570/2, 2nd Block, 7th Main, 80 Feet Road, Subbannapalya, Banaswadi, Bengaluru - 560 043.

Mobile : 96633 75929

Report No. : 14 / M/S / 03 14
NAME OF CLIENT :

M/S B B M P

Sir/Madam,

1. Geological Investigation Date : 02/03/14
(a) Location [Survey No. Village, Area etc.]
(b) district

Ward. No. 5th
Shirampura 4th Cross

2. Purpose of Borewell : Drining / Irrigation / Industry etc.,
3. Well Inventory Study within 250 m : Good
4. Re-charge Conditions : Nodestake

Ground water - Technical Details

1. Area Investigation Slopes Towards :

South

2. Topology : Plain / Uneven / Undulated

3. Soil Texture :

Braon & Sandp

4. Lithology / Geology of area :

Granite

5. VES Details If geo-physical data

NA

6. Location is : Feasible / Not feasible

feasible

7. Dia of Borewell :

6 1/2"

8. Depth Recommended :

330 M

9. Casing Pipe required :

30 M

10. Method of Installation :

12 M

11. PVC outer casing [if reqd] :

12. Aquifer Zones : (a) 270 - 280 M

(b) 320 - M

13. Yield estimated (approx) : About 1100 GPH

14. Location shown to :

The party

Assistant Executive Engineer,
Bretarajapalya Sub Division
B.B.M.P. Bangalore

R. Kannabiran
(KANNABIRAN .R. M.Sc.)
(Geologist)

ಶ್ರೀ ಗೋಕುಲ
ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

WELL - LOG

- 1, Name of drilling organization; For Sri Balaji Drilling Contractors
- 2, Name of client ; **BBMP**
- 3, Date of drilling ; 9.3.14.
- 4, Area a) Ward No.;
b) Location; S.
Srirampura. 4th cross.
- 5, Depth of Borewell; 335.26 mtr.
- 6, Casing pipe Outer PVC; 12.17 mtr.
- 7, Casing pipe MS erected; 32.00 mtr.
- 8, Collars used (no); 5 nos.
- 9, Rock Strata; Granite
- 10, Estimated Yield (Airline method); 1200 Gph.
- 11, Pump recomanded; HP Stage.
- 12, Remarks if any; Soft & clear
- Seal and signature of Hydro-Geologist

AE-05
ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

[Signature]
Assistant Executive Engineer
Syatarayanapura Sub Division
B.B.M.P. Bangalore

R. KANNABIRAN M.Sc.,
[Signature]
Hydro - Geologist